

Approval Number 251255009
Test Report: MA00001\Sa & MA00001\Sb-001



7th October 2025

Palaplast S.A.
Industrial Area of Sindos,
Thessaloniki,
57022,
Greece

Water Regulations Approval Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

WATER REGULATIONS APPROVAL SCHEME LTD. (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

POLYPROPYLENE- COMPONENTS.

5260

'Palaplast Thermopal PP-R Fitting'. Green coloured, injection moulded polypropylene fitting. For use with water up to 23°C.

APPROVAL NUMBER: 251255009

APPROVAL HOLDER: PALAPLAST S.A.

This is a re-approval of 2011547 which is valid between November 2020 and November 2025.

The Scheme reserves the right to review approval.

Approval 251255009 is valid between December 2025 and December 2030

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wrasapprovals.co.uk/approvals-directory/

Yours Faithfully

Ian Hughes
WRAS Approvals Manager